CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-1178:100 Page 1 of 2

CATEGORY: Annunciator

LISTEE: Kirkland, 4935 Allison St., Suite 13, Arvada, CO 80002

Contact: Tricia Kirkland (800) 247-2303 FAX (303) 420-1856

DESIGN: Graphic or directory annunciators. Models list as follows:

\sim D	^	\mathbf{r}	-	\sim
GR	Д	Рŀ	-11	ι.

4602-9511-GP2	4602-9511	4602-9514
4602-9511-GP4	4602-9512-GP2	4602-9512
4602-9515	4602-9512-GP4	4602-9506-GP2
4602-9506	4602-9509	4602-9506-GP4
CTI-33	BGRA-GR-GP2	BGRB-GR-GP2
RSA-GR-GP2	RSB-GR-GP2	RSC-L-GR-GP2
RSC-GR-GP2	RSD-GR-GP2	RSE-GR-GP2
RSE-L-GR-GP2	CEF-GR-GP2	CEF-L-GR-GP2
BGRA-GR-GP3	BGRB-GR-GP3	RSA-GR-GP3
RSB-GR-GP3	RSC-L-GR-GP3	RSC-GR-GP3
RSD-GR-GP3	RSE-GR-GP3	RSE-L-GR-GP3
CEF-GR-GP3	CEF-L-GR-GP3	BGRA-GR-GP4
BGRB-GR-GP4	RSA-GR-GP4	RSB-GR-GP4
RSC-L-GR-GP4	RSC-GR-GP4	RSD-GR-GP4
RSE-GR-GP4	BGRA-GR-GP6	BGRB-GR-GP6
RSA-GR-GP6	RSB-GR-GP6	RSC-L-GR-GP6
RSC-GR-GP6	RSD-GR-GP6	RSE-GR-GP6
RSG-GR-GP6	RSG-L-GR-GP6	RSE-L-GR-GP
RSE-L-GR-GP6	RSG-GR-GP4	RSG-L-GR-GP4
CEF-GR-GP4	CEF-GR-GP6	CEF-L-GR-GP4
CEF-L-GR-GP6		

DIRECTORY

BGRA-D-16	BGRA-D-32	BGRB-D-40
BGRB-D-48	BGRB-D-64	RSC-D-80
RSC-D-100	RSD-D-144	RSC-D-154
RSD-D-160		

Refer to listee's data sheet for detailed product description and operational considerations.

*Rev. 05-07-97

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes &

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed graphic and directory annunciators for use with separately listed compatible fire

alarm control units. For indoor use only.

NOTE: Formerly 7300-1178:100





This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 22, 2004 Listing Expires June 30, 2005

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager